

Scala, Mary Joy

From: Benjamin Myrtle <benmyrtle@gmail.com>
Sent: Monday, May 20, 2013 3:38 PM
To: Scala, Mary Joy
Subject: Permit # BN-13-0227
Attachments: Photo374.jpg; Photo375.jpg; Photo376.jpg

Dear Mrs. Scala,

I have confirmed with the roofing subcontractor the specs. for the Englert metal roofing system to be installed.

Pan spacing will be 17" - like existing.

Seam height will be 1" - like existing.

Ridge will be "pan lock seam" - like existing.

Color to be "Hartford Green". [Englert Color Chart](#)

Please contact me with any questions or directives. Thank you for your time.

Sincerely, Ben

--

RECS

Real Estate & Construction Services

Benjamin T. Myrtle

(434) 466 - 6371

Disclosure: "RECS" is not a brokerage. Benjamin Myrtle is licensed to sell Real Estate in the State of Virginia through 1st Dominion Realty.

