

Scala, Mary Joy

From: Scala, Mary Joy
Sent: Monday, June 02, 2014 10:51 AM
To: Weatherford, Brenda
Subject: FW: 801 W Main

Mary Joy Scala, AICP

Preservation and Design Planner
City of Charlottesville
Department of Neighborhood Development Services
City Hall – 610 East Market Street
P.O. Box 911
Charlottesville, VA 22902
Ph 434.970.3130 FAX 434.970.3359
scala@charlottesville.org

From: Darrell Bailey [<mailto:dbailey@bakerroofing.com>]
Sent: Monday, June 02, 2014 10:50 AM
To: Scala, Mary Joy
Subject: RE: 801 W Main

Yes, that is correct, we will work to closely match the existing. As with most paint matches to old construction, there will probably be some small visual difference due to having to match the old weathered fascia.

Thanks for forwarding the folder. I will be in either tomorrow or Wednesday to sign and pay the fee.

Darrell

Darrell G. Bailey
General Manager
Baker Roofing of Harrisonburg, LLC
Tel: 540-746-7046
Fax: 540-234-0380
Email: dbailey@bakerroofing.com
Website: www.bakerroofing.com

From: Scala, Mary Joy [<mailto:scala@charlottesville.org>]
Sent: Monday, June 02, 2014 10:44 AM
To: Darrell Bailey
Subject: RE: 801 W Main

OK Thank you. I assume the new metal will be painted to match also.


I'll tell Brenda Weatherford that you are going to apply, and will give her the folder.

Mary Joy Scala, AICP

Preservation and Design Planner
City of Charlottesville



This is the only visible element of the fascia / coping that will be changed. The new will be formed to match this.



This metal fascia, which is pulling back from the edge due to roof failure, will be replaced with the same profile. The face of this existing metal is flat with a 1/2" bend at the bottom that serves to hook into a concealed cleat that helps anchor the edge.